

# Certificate

## EC-Certificate of Conformity

**Certificate No. 0086-CPD-575041**

In compliance with the Directive 89/106/EEC of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (the Construction Products Directive or CPD), as later amended, it has been stated that the construction product

### **Control and Indicating Equipment and Power Supply Equipment**

as detailed on the Supplementary Information Sheet

placed on the market by

#### **Zeta Alarm Systems by GLT Exports Limited**

Detection House, 72 - 78 Morfa Road, Swansea, SA1 2EN, United Kingdom

And produced in the factory

#### **Zeta Alarm Systems by GLT Exports Limited**

Detection House, 72 - 78 Morfa Road, Swansea, SA1 2EN, United Kingdom

is submitted by the manufacturer to a factory production control and that the notified body 0086 British Standards Institution has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of factory production control and performs the continuous surveillance, assessment and approval of factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard(s)

### **EN 54-2:1997 + A1 + AC and EN 54-4:1998 + A1 & A2**

were applied and that the product fulfils the prescribed requirements.

This certificate was first issued on 08 October 2012 and remains valid as long as the conditions laid down in the harmonised standard in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

For and on behalf of BSI, a Notified Body for the above Directive (Notified Body Number 0086).



Gary Fenton, Global Assurance Director

Latest Issue: 13 November 2012

Page 1 of 2

This certificate remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the factory product control itself are not modified significantly.

*raising standards worldwide™*



# Certificate

## SUPPLEMENTARY INFORMATION SHEET

Certificate No. 0086-CPD-575041

Zeta Alarm Systems by GLT Exports Limited

### Product Information

Model Reference	Type
-----------------	------

IN1	Infinity 1 Zone Conventional Control and Indicating Equipment
IN2	Infinity 2 Zone Conventional Control and Indicating Equipment
IN4	Infinity 4 Zone Conventional Control and Indicating Equipment
IN6	Infinity 6 Zone Conventional Control and Indicating Equipment
IN8	Infinity 8 Zone Conventional Control and Indicating Equipment

*Certified for use with Zeta Alarm Systems conventional fire detection and alarm devices.*

### Options with requirements

Certified with the following options with requirements from BS EN 54 Part 2: 1997:

Output to fire alarm devices (clause 7.8)  
Delays to outputs (clause 7.11)  
Test condition (clause 10)

