

## Certificate of constancy of performance,

**0832-CPR-F0069**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **MKII-OH Fyreye II Conventional optical and heat detector**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

### **Zeta Alarms by GLT Exports Ltd**

**Detection House  
72-78 Morfa Road  
Swansea  
SA1 2EN  
UK**

and produced in the manufacturing plant(s)

**CC0346**


This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors  
EN 54-5:2000 + A1:2002 - Heat detectors - Point detectors**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 12 July 2013 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Martin McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 16 July 2013  
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR- F0069

**Bases:**


- a) MKII-CB/D Deep base
- b) MKII-CB Shallow base

**Sensitivities:**

Smoke Sensitivity setting Range: 0.08%dB~0.12%dB

**Heat Classifications:**

- b) A2



Martin McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 16 July 2013  
Issue number: 02

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).