

EC-Certificate of Conformity Certificate No. 0086-CPD-553648



In compliance with the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Fire Alarm Devices - Sounders

as detailed on the Supplementary Information Sheet

placed on the market by

Zeta Alarm Systems by GLT Exports Limited

Detection House, 72 – 78 Morfa Road, Swansea, SA1 2EN, United Kingdom

and produced in the factory

Zeta Alarm Systems by GLT Exports Limited

Detection House, 72 – 78 Morfa Road, Swansea, SA1 2EN, United Kingdom

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body BSI has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the Standard

EN 54-3: 2001 + A1 & A2

were applied and that the product fulfils the prescribed requirements.

For and on behalf of the British Standards Institution, a Notified Body for the above Directive.
Notified Body Number 0086.

David W. Ford, Executive Director, Healthcare and Testing Services

First Issued: 24 August 2010

Date: 16 September 2010

Page 1 of 2

This certificate remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the factory product control itself are not modified significantly.

*raising standards worldwide*TM
The British Standards Institution is incorporated by Royal Charter.



Certificate

SUPPLEMENTARY INFORMATION SHEET

Certificate No. 0086-CPD-553648

Zeta Alarm Systems by GLT Exports Limited

Product Information

BS EN 54 Part 3: 2001 – Fire alarm devices - sounders

Model Reference	Type
ZMT/8	Maxitone Type A 103dBA Conventional Indoor sounder
ZAMT	Maxitone Type A 94dBA Addressable Indoor sounder

The Maxitone ZMT/8 Conventional Sounder has been certified for use with the following sound pattern:

No.	Sound Pattern Description	Sound Pattern / Frequencies
1	Alternating Tone	800 Hz / 970 Hz, 0.25s / 0.25s

The Maxitone ZAMT Addressable Sounder has been certified for use with the following sound pattern:

No.	Sound Pattern Description	Sound Pattern / Frequencies
1	Alternating Tone	800 Hz / 970 Hz, 0.5s / 0.5s

First Issued: 24 August 2010

Date: 16 September 2010

Page 2 of 2

*raising standards worldwide*TM

