Issue date: 2017-09-29



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

FEOE2000 Conventional Smoke detector with output for LED OPTICAL SMOKE

The product fulfils the essential characteristic:

See Annex 1

Intended use:

Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Zeta Alarms Limited 72-78 Morfa Road, Haford, Swansea, SA1 2EN, United Kingdom

and produced in the manufacturing plant:

CPA10001

:

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN54-7:2000/A1:2002/A2:2006

Fire detection and fire alarm systems – Part 7: Smoke detectors – Point detectors using scattered light, transmitted light or ionization

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2017-09-29

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2017-03-10)

This certificate was first issued 2014-08-01.

Klaus Mühlbach Responsible for evaluation

Merete Poulsen Responsible for certification decision

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.

DBI Certification A/S Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk



Version 2015-10-23 Page **1** of **4**

Issue date: 2017-09-29



Annex 1

EXTENT

Type: Fyreye detector type FEOE2000 OPTICAL SMOKE Conventional Smoke detector with output for LED Must be installed in Fyreye Common Base Part no. 45681-200GLT.

Performance

| Nominal activation conditions/Sensitivity, Response delay (response time) and Performance under fire conditions4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18PassOperational reliability Tolerance to supply voltage4.2 to 4.7, 4.9 to 4.11PassDurability of operational reliability and response delay; temperature resistance5.5PassDurability of operational reliability, vibration resistance5.13, 5.16PassDurability of operational reliability, humidity resistance5.10, 5.11PassDurability of operational reliability, for operational reliability, for operational5.12PassDurability of operational reliability of operational5.17Pass | Essential characteristics | Clauses in EN 54-7:2000 | Performance |
|---|-----------------------------------|------------------------------------|-------------|
| delay (response time) and Performance under fire conditions4.2 to 4.7, 4.9 to 4.11PassOperational reliability4.2 to 4.7, 4.9 to 4.11PassTolerance to supply voltage5.5PassDurability of operational reliability and response delay; temperature resistance5.8, 5.9PassDurability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | Nominal activation | 4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18 | Pass |
| Performance under fire conditionsOperational reliability4.2 to 4.7, 4.9 to 4.11PassTolerance to supply voltage5.5PassDurability of operational reliability and response delay; temperature resistance5.8, 5.9PassDurability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; humidity resistance5.12Pass | | | |
| Operational reliability4.2 to 4.7, 4.9 to 4.11PassTolerance to supply voltage5.5PassDurability of operational reliability and response delay; temperature resistance5.8, 5.9PassDurability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; humidity resistance5.12Pass | | | |
| Tolerance to supply voltage5.5PassDurability of operational reliability and response delay; temperature resistance5.8, 5.9PassDurability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | | | |
| Durability of operational reliability and response delay; temperature resistance5.8, 5.9PassDurability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | | 4.2 to 4.7, 4.9 to 4.11 | Pass |
| and response delay; temperature resistance5.13, 5.16PassDurability of operational reliability; vibration resistance5.10, 5.11PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | | | Pass |
| resistanceSecond Second Se | | 5.8, 5.9 | Pass |
| Durability of operational reliability; vibration resistance5.13, 5.16PassDurability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | | | |
| reliability; vibration resistance Pass Durability of operational reliability; humidity resistance 5.10, 5.11 Pass Durability of operational reliability; corrosion resistance 5.12 Pass | | | |
| Durability of operational reliability; humidity resistance5.10, 5.11PassDurability of operational reliability; corrosion resistance5.12Pass | | 5.13, 5.16 | Pass |
| reliability; humidity resistance Pass Durability of operational 5.12 Pass reliability; corrosion resistance Pass Pass | | | |
| Durability of operational 5.12 Pass reliability; corrosion resistance | | 5.10, 5.11 | Pass |
| reliability; corrosion resistance | | | |
| | | 5.12 | Pass |
| Durability of operational 5.17 Pass | | | |
| | Durability of operational | 5.17 | Pass |
| reliability; electrical stability | reliability; electrical stability | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



DBI Certification A/S

Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90 E-mail: info@dbicertification.dk www.dbicertification.dk

Issue date: 2017-09-29



Annex 2

TEST DOCUMENTATION

| Accredited Laboratory | Report no. | Date |
|-----------------------|----------------------|------------|
| | | |
| DELTA | DANAK-199813, Rev. 1 | 2007-01-11 |
| DELTA | DANAK-199728 | 2004-06-04 |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



DBI Certification A/S Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk

Issue date: 2017-09-29



Annex 3

TECHNICAL BASIS

| File Number | Title | Date |
|--------------------------------------|-------------|------------|
| WizMart | GLT323D001, | 2006-11-13 |
| FEOE2000 & | Version 1.1 | |
| FEOH2000 document | | |
| - For DBI Certificate Application | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



DBI Certification A/S

Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk

Version 2015-10-23 Page 4 of 4