Issue date: 2017-09-29



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

FEAOE2000 OPTICAL Analogue addressable Smoke detector with output for SMOKE LED

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Zeta Alarms Limited 72-48 Morfa Road, Haford, Swansea, SA1 2EN, United Kingdom

and produced in the manufacturing plant:

CPA10001

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN54-7:2000/A1:2002/A2:2006 : Fire detection and fire alarm systems –

Part 7: Smoke detectors - Point detectors using scattered light,

transmitted light or ionization

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2017-09-29

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2017-03-10)

This certificate was first issued 2014-08-01.

Klaus Mühlbach Responsible for evaluation Merete Poulsen Responsible for certification decision

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.

Prod. Reg. Nr. 7023

Issue date: 2017-09-29



Annex 1

EXTENT

Type:

Fyreye detector type FEAOE2000 OPTICAL SMOKE Analogue addressable smoke detector with output for LED Must be installed in Fyreye Common Base Part no. 45681-200GLT.

Performance

Essential characteristics	Clauses in EN 54-7:2000		Performance	
Nominal activation	4.8, 5.2, 5.3, 5.4, 5.6, 5.7, 5.18		Pass	
conditions/Sensitivity, Response				
delay (response time) and				
Performance under fire conditions				
Operational reliability	4.2 to 4.7, 4.9 to 4.11			Pass
Tolerance to supply voltage		5.5		Pass
Durability of operational reliability		5.8, 5.9		Pass
and response delay; temperature				
resistance				
Durability of operational		5.13, 5.16		Pass
reliability; vibration resistance				
Durability of operational	5.10, 5.11			Pass
reliability; humidity resistance				
Durability of operational		5.12		Pass
reliability; corrosion resistance				
Durability of operational		5.17		Pass
reliability; electrical stability				

Issue date: 2017-09-29



Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date	
DELTA	DANAK-199813, Rev 1.	2007-01-11	
DELTA	DANAK-199748	2005-04-21	

Issue date: 2017-09-29



Annex 3

TECHNICAL BASIS

File Number	Tit	le	Date
WizMart	RD06-GLT00,		2006.11.14
	Version 1.1		
GLT-FEA2000			
document			
- For DBI Certificate			
Application			