Issue date: 2018-01-11



### **CERTIFICATE OF CONSTANCY OF PERFORMANCE**

Issued by DBI Certification, notified body No. 2531.

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## ZT-CP3 Manual Call Point for outdoor use, IP67

The product fulfils the essential characteristic:

#### See Annex 1

Intended use:

Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Zeta Alarms Limited 72-78 Morfa Road, Haford, Swansea, SA1 2EN, United Kingdom

and produced in the manufacturing plant:

CPA10012

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-11:2001	:	Fire Detection and fire alarm s	ystems –
EN 54-11:2001/A1:2005		Part 11:Manual Call Points.	

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2018-01-11.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

(This certificate supersedes the previous version of this certificate issued 2014-04-24)

This certificate was first issued 2014-08-01.

Merete Poulsen Responsible for evaluation

Klaus Mühlbach Responsible for certification decision

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.

**DBI Certification A/S** Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk



Version 2015-10-23 Page **1** of **4** 

Issue date: 2018-01-11



Annex 1

#### EXTENT

## Type:

ZT-CP3 Manual Call Point for outdoor use, IP67

#### Performance

Essential characteristics	Clauses in EN 54-11:2001/ A1:2005	Performance	
Nominal activation	4.3.2, 4.4, 4.7.1, 4.7.4, 5.2,	Pass	
conditions/Sensitivity and	5.3		
Performance under fire			
conditions			
Operational reliability	4.4 to 4.11	Pass	
Durability of operational	5.7, 5.19	Pass	
reliability temperature			
resistance			
Durability of operational	5.14 to 5.17	Pass	
reliability; vibration resistance			
Durability of operational	5.10, 5.12, 5.19	Pass	
reliability; humidity resistance			
Durability of operational	5.11, 513	Pass	
reliability; corrosion resistance			
Durability of operational	5.6, 5.18	Pass	
reliability; electrical stability			

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



**DBI Certification A/S** Jernholmen 12, 2650 Hvide

Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90 E-mail: info@dbicertification.dk www.dbicertification.dk

Issue date: 2018-01-11



Annex 2

### TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
DELTA	DANAK-1910744 Rev. B Project no.: A530602	2010-10-01

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



**DBI Certification A/S** Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk

Version 2015-10-23 Page **3** of **4** 

Issue date: 2018-01-11



Annex 3

### **TECHNICAL BASIS**

File Number	Title
Drawing Register	Drawing Register 0845-CPR-232_1688

The certificate shall be reproduced in extenso – extracts only with written permission from DBI Certification A/S.



DBI Certification A/S

Jernholmen 12, 2650 Hvidovre Tlf.: 36 34 90 90

E-mail: info@dbicertification.dk www.dbicertification.dk

Version 2015-10-23 Page 4 of 4