



MANUFACTURERS OF FIRE ALARM EQUIPMENT

DECLARATION of CONFORMITY

The manufacturers (Zeta Alarms Ltd, 72-78 Morfa Road, Swansea, SA1 2EN) declares that

QUATRO 4-8 LOOP PANEL WITH PRINTER

37-584	QT/4-8P	Premier Quatro 4 loop Fire Alarm Panel with printer
37-585	QT/5-8P	Premier Quatro 5 loop Fire Alarm Panel with printer
37-586	QT/6-8P	Premier Quatro 6 loop Fire Alarm Panel with printer
37-587	QT/7-8P	Premier Quatro 7 loop Fire Alarm Panel with printer
37-588	QT/8-8P	Premier Quatro 8 loop Fire Alarm Panel with printer

Complies to the following standards:

Emission: EN61000-6-3 :2007

Immunity: EN50130-4 :2003

European Standard: EN54 Parts 2 and 4

and thereby, complies with the ESSENTIAL REQUISITES of DIRECTIVE 2004/108/EC



A handwritten signature in blue ink, appearing to be "D. Zachariah", is written over a faint, stylized star-like graphic.

For and on behalf of
Zeta Alarms Ltd
D. Zachariah
QUALITY ASSURANCE
MANAGER

Date: 11.09.2017