

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011 &
UKCA Statutory Instrument (SI)465/2019

DoP Ref: GLT-279-DoP-2

1. Unique Product identification code:

42-637 , 42-638

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

ZRAPB/R , Zeta Addressable Raptor Sounder Beacon, Red Plastic, White Flash

ZRAPB/W , Zeta Addressable Raptor Sounder Beacon, White Plastic, White Flash

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings. (Indoor or outdoor use)

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Zeta Alarms Limited

72-78 Morfa Road

Swansea

SA1 2EN

UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

BRE GLOBAL, IRELAND (Identification No 2831) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

2831-CPR-F2048

BRE GLOBAL. (Identification No 0832) have issued the following UKCA certification in accordance with UKCA SI 465/2019.

0832-UKCA-CPR-F1881

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7

9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Performance	Harmonized Technical Specification	
		EN54-3:2001 + A1:2002 + A2:2006	EN54-23:2010
Performance under fire conditions	Pass	4.2 - Sound level	4.3.1 – Coverage Volume
		4.3 - Frequency and sound pattern	4.3.5 – light temporal pattern and flash frequency
		5.2 - Reproducibility	5.1.7- Reproducibility
Operational reliability	Pass	4.5 - Construction	4.2.2 – Provision for external conductors
		4.6 - Marking and data	4.3.6 – Marking and data
		5.4 - Durability	4.2.1- Duration of operation
Durability of operational reliability, Temperature resistance	Pass	5.5 - Dry heat (operational)	4.4.1.1- Dry heat (operational)
		5.6 - Dry heat (Endurance)	4.4.1.2- Dry heat (Endurance)
		5.7 - Cold (operational)	4.4.1.3- Cold (operational)
		5.8 - Damp heat, cyclic (operational)	4.4.2.1- Damp heat, cyclic (operational)
Durability of operational reliability, Humidity resistance	Pass	5.8 - Damp heat, cyclic (operational)	4.4.2.3 - Damp heat, cyclic (endurance)
		5.9 - Damp heat, steady state (endurance)	4.4.2.2- Damp heat, steady state (endurance)
Durability of operational reliability, Corrosion resistance	Pass	5.11 - Sulphur dioxide (SO ₂) corrosion (endurance)	4.4.4 – Sulphur dioxide (SO ₂) corrosion (endurance)
Durability of operational reliability, Shock and Vibration resistance	Pass	5.12 - Shock (operational)	4.4.3.1- Shock (operational)
		5.13 - Impact (operational)	4.4.3.2- Impact (operational)
		5.14 - Vibration, sinusoidal (operational)	4.4.3.3- Vibration, sinusoidal (operational)
		5.15 - Vibration, sinusoidal (endurance)	4.4.3.4- Vibration, sinusoidal (endurance)
Durability of operational reliability, Electrical stability	Pass	5.16 - EMC immunity tests (operational)	4.4.5 – Electrical stability
Durability of operational reliability, Resistance to Ingress	Pass	5.17 - Enclosure protection	4.2.4 – Enclosure protection

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of **Zeta Alarms Limited** by:

Name: **N.R. P. Jones**

Signature:



Position: **Technical Manager**

Place of issue: **Swansea**

Date of issue: **17th August, 2026**