

DECLARATION OF PERFORMANCE

According to Construction Products Regulation EU N° 305/2011 & UKCA Statutory Instrument (SI)465/2019

DoP Ref: GLT- 212-DoP-1

1. Unique Product identification code:

37-096

2. Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):

EX-PRO Premier EX Pro, 2 zone 1 area extinguishing control panel.

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems installed in and around buildings. (Indoor use only)

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):

Zeta Alarms Limited 72-78 Morfa Road Swansea SA1 2EN, UK

5. Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):

Not applicable

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by the harmonized standard:

BSI Group The Netherlands B.V. Say Building, John M. Keynesplein 9, 1066 EP, Amsterdam. Netherlands (Identification NO 2797) performed type testing and the initial inspection of the manufacturing plant and of the factory production control with continuous surveillance assessment and approval of the factory production control under system 1 and issued the EC certificates of conformity:

2797-CPR-670813

BSI. Kitemark House, Maylands Avenue, Hemel Hempstead, HP2 4SQ (Identification No 0086) have issued the following UKCA certification in accordance with UKCA SI 465/2019.

0086-UKCA-CPD-670813

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:

Not applicable, see item 7



9. Declared performance:

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses indicated in 3. have been determined as described in the hEN mentioned in the following table.

Essential characteristics	Perform ance	Harmonized Technical Specification		
		EN 54-2: 1997 + A1: 2006	EN E4 4: 1007 : A2: 2006	
Operational valiability.	Desc		EN 54-4: 1997 + A2: 2006	
Operational reliability	Pass	4 - General requirements	4 - General requirements	
		5 - General requirements for	5 – Functions	
		indications		
		6 - The quiescent condition	6 - Materials, design and manufacture	
		7. The fire alarms are distant		
		7 - The fire alarm condition	7 - Documentation	
		8 - Fault warning condition		
		9 - Disabled condition		
		10 - Test condition (option with		
		requirements)		
		12 - Design requirements		
		13 - Additional design requirements for		
		software controlled control and		
		indicating equipments		
	_	14 - Marking	8 - Marking	
Durability of operational	Pass	15.4 - Cold (operational)	9.5 - Cold (operational)	
reliability Temperature resistance				
Durability of operational	Pass	15.6 - Impact (operational)	9.7 - Impact (operational)	
reliability Vibration resistance		15.7 - Vibration, sinusoidal	9.8 - Vibration, sinusoidal	
		(operational)	(operational)	
		15.15 - Vibration, sinusoidal	9.15 - Vibration, sinusoidal	
		(endurance)	(operational)	
Durability of operational	Pass	15.8 - Electromagnetic Compatibility	9.9 - Electromagnetic	
reliability Electrical stability		(EMC), Immunity tests (operational)	Compatibility (EMC), Immunity	
			tests (operational)	
		15.13 - Supply voltage variation		
		(operational)		
Durability of operational reliability Humidity resistance	Pass	15.5 - Damp heat, steady state	9.6 - Damp heat, steady state	
		(operational)	(operational)	
		15.14 - Damp heat, steady state	9.14 - Damp heat, steady state	
		(endurance)	(endurance)	
Performance under fire conditions	Pass	4 - General requirements		
		5 - General requirements for		
		indications		
		7 - The fire alarm condition		
Response delay (response time to	Pass	7.1 - Reception and processing of fire		
fire)		signals		
		7.7 - Output of the fire alarm condition		
		7.11 - Delays to outputs (option with		
		requirements)		
Performance of power supply	Pass		4 - General requirements	
			5 – Functions	
			6 - Materials, design and	
			manufacture	



Essential characteristics	Performance	Harmonized Technical Specification
		EN 12094-1: 2003
Operational reliability	Pass	4.1 - General requirements
		4.6 – Activation of Alarm Devices
		4.8 – Activated Condition
		4.10 – Released Condition
		4.15 - Disabled condition
		5 - Design requirements
		6 - Additional design requirements for software controlled
		E.C.D.S
		7 - Marking
Durability of operational reliability	Pass	9.5 - Sulphur dioxide (SO2) corrosion (endurance)
Corrosion		
Durability of operational reliability	Pass	9.4 - Damp heat, cyclic (operational)
Humidity resistance		

EN54-2 OPTIONAL FUNCTIONS (OPTIONS WITH REQUIREMENTS)				
7.8	Pass	7.8 - Output to fire alarm Devices		
10	Pass	10 - Test Condition		

BSEN12094-1: OPTIONAL FUNCTIONS (OPTIONS WITH REQUIREMENTS)				
4.17	Pass	Delay of extinguishing signal		
4.18	Pass	Signal representing the flow of extinguishing agent		
4.21	Pass	Control of flooding time		
4.23	Pass	Manual Only Mode		
4.26	Pass	Triggering of equipment outside the system		
4.27	Pass	Emergency Abort Device		
4.30	Pass	Activation of alarm devices with different signals		

10. The performance of the product identified in 1. and 2. is in conformity with the declared performance in 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in 4.

Signed for and on behalf of Zeta Alarms Limited by:

Name: N.R. P. Jones

Signature:

Position: Technical Manager

Place of issue: Swansea

Date of issue: 01st November 2022